


SUMMARY OF RESULTS OF TESTING CERTIFICATE

NUMBER	0551	DATE	04 / 08 / 05
---------------	------	-------------	--------------

Client' s data:	PROFILCO S.A. ALUMINIUM EXTRUSION INDUSTRY 11 th km Nat.Road ATHENS - LAMIA GR 144 52 METAMORFOSI ATTIKIS - GREECE
Product description:	DOUBLE SASH WINDOW TILT & TURN
Material:	ALUMINIUM
System :	THERMO PR 63



994 x 1194 mm

Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 4
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class E 2100
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C5

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



SINOPI PAPAPOPOULOU
TECHNICAL MANAGER



IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL